

# Adapter set NKT SS

For medium voltage connectors

CAPDIS adapter sets, together with CAPDIS Voltage Detecting Systems, enable testing for absence of voltage on medium-voltage cable fittings within the framework of the five safety rules and in compliance with IEC 62271-213. The CAPDIS adapter set couples out the voltage signal at the C1 capacitance of the medium-voltage cable fitting. A CAPDIS Voltage Detecting Systems is connected via a suitable connecting cable. This enables a professional check for absence of voltage. Likewise, this voltage signal can be used in conjunction with IKI fault indicators for the directional detection of short circuits and earth faults.



## Applications

CAPDIS adapter sets can be used in various installation situations. A separate CAPDIS adapter set is assigned to each of the medium-voltage connectors (see table).

- SF6 switchgears with defective or non-existent capacitive tap
- Separate Voltage Detecting Systems on transformers

## Variants for NKT medium-voltage connectors

Item number	Description
2041829	NKT busbar measurement
2500161_NKT	NKT CB12,24,36-630   Type C   C1 = 1.5 pF
2500162	NKT EASW 20-250   Type A   C1 = 1 pF
2500163_AK4_NKT	NKT CE 24-250/400   Type A/B   C1 = 1 pF

## Technical data

### Article data

Article number	2041829
Quantity unit	Set with 3 pieces
Product designation	NKT busbar measurement



**Kries-Energietechnik GmbH & Co. KG**  
Sandwiesenstr. 19 | D-71334 Waiblingen  
kries.com | service@kries.com | +49 7151 96932 0

© Kries-Energietechnik GmbH & Co. KG | Subject to modifications.

19.08.22

Page 1/2

# Adapter set NKT SS

For medium voltage connectors

## Operating conditions

Operating temperature	-25°C ... 55°C
Storage temperature	-30°C ... 75°C
Voltage level	1..52 kV (Medium-voltage)
Rated frequency	50 Hz, 60 Hz
Type of interface	LRM

## Compatible medium-voltage connectors

NKT: Busbar measurement	x
-------------------------	---

## Ordering information

CAPDIS devices, C2m modules and cable set must be ordered separately. A calculation of the suitable C2m value is recommended due to the typically low C1 value.

