

Adapter set Südkabel SEIK

For medium voltage connectors

CAPDIS adapter sets, together with CAPDIS Voltage Detecting Systems, enable testing for absence of voltage on medium-voltage cable fittings within the framework of the five safety rules and in compliance with IEC 62271-213. The CAPDIS adapter set couples out the voltage signal at the C1 capacitance of the medium-voltage cable fitting. A CAPDIS Voltage Detecting Systems is connected via a suitable connecting cable. This enables a professional check for absence of voltage. Likewise, this voltage signal can be used in conjunction with IKI fault indicators for the directional detection of short circuits and earth faults.



Applications

CAPDIS adapter sets can be used in various installation situations. A separate CAPDIS adapter set is assigned to each of the medium-voltage connectors (see table).

- SF6 switchgears with defective or non-existent capacitive tap
- Separate Voltage Detecting Systems on transformers

Variants for Suedkabel medium-voltage connectors

Item number	Description
2500196	Suedkabel SEHDT 23 plastic encapsulation type C C1 = 1.2 pF
2500385	Suedkabel SEIK C1 = 1.5 pF
2500392	Suedkabel SEHDW 21 Type A C1 = 1.5 - 1.7 pF
2500397	Suedkabel SET plastic encapsulation C1 = 1.6 pF

Technical data

Article data

Article number	2500385
Quantity unit	Set with 3 pieces
Product designation	Suedkabel SEIK C1 = 1.5 pF



Kries Energietechnik GmbH & Co. KG

Sandwiesenstr. 19 | D-71334 Waiblingen

kries.com | sales.kries@te.com | (+)49-7151-7074-860

© Kries Energietechnik GmbH & Co. KG | Subject to modifications.

22.08.24

Page 1/2

Adapter set Südkabel SEIK

For medium voltage connectors

Operating conditions

Operating temperature	-25°C ... 55°C
Storage temperature	-30°C ... 75°C
Voltage level	1..52 kV (Medium-voltage)
Rated frequency	50 Hz, 60 Hz
Type of interface	LRM

Compatible medium-voltage connectors

Suedkabel: SEIK	x
-----------------	---

Ordering information

CAPDIS devices, C2m modules and cable set must be ordered separately. A calculation of the suitable C2m value is recommended due to the typically low C1 value.



Kries Energietechnik GmbH & Co. KG

Sandwiesenstr. 19 | D-71334 Waiblingen

kries.com | sales.kries@te.com | (+)49-7151-7074-860

22.08.24

Page 2/2